

**ADDENDUM NO. ONE**  
**REQUEST FOR QUOTATION**  
**POLICE WEAPONS EVIDENCE STORAGE**  
**PROJECT NO. 128-23**  
**CITY OF THORNTON, CO**

TO: Prospective Proposing Firms and all others concerned

DATE: March 2, 2023

PURPOSE: To provide additional information and clarification to the solicitation documents for the above-referenced Project.

1. The following questions and answers are provided for additional clarification to the RFQ.

Question 1: What is the ceiling height of the room?

**Answer 1: Due to fire suppression and ducting, the wall height on the rifle side of the room is 10.5'. The height on handgun side of the room is 10'.**

Question 2: What is the sprinkler height of the room? Fire codes typically require 18" of clearance.

**Answer 2: 12' only on the handgun side of the room.**

Question 3: Is the entry door located on the 92" wall? Is Thornton willing to move the door to maximize storage capacity? What is the dimensions of the door?

**Answer 3: The long walls are on the north and south ends of the room, and the short walls are on the east and west ends of the room. The entry door is on the west end of the room and the storage room is accessible from a hallway.**

**No, Thornton is not willing to move the door, as there is a light switch on the interior of the west wall, along with a fire alarm.**

**The door opening measurement in 34.75"x94".**

Question 4: What floor is the storage room located on?

**Answer 4: The second floor.**

Question 5: Is the floor concrete?

**Answer 5: Yes.**

Question 6: Is there an approximate ratio of boxed and unboxed guns for both handguns and long guns?

**Answer 6: There are approximately fifteen (15) long guns currently unboxed and there are no handguns that are unboxed or at least not in a current cabinet.**

Question 7: Does the building have a loading dock?

**Answer 7: Yes, along with an elevator inside the building.**

Question 8: Is Thornton willing to relocate the fire alarm switch location to the right of the entry doorway another two inches (2") closer to the doorway?

**Answer 8: No.**

2. The Pre-Proposal Sign-in Sheet is attached for additional information.
3. All other terms and conditions shall remain unchanged except as provided by this Addendum. Proposing firms must acknowledge receipt of this Addendum in their Bid.

***END OF ADDENDUM NO. ONE***

---

Megan deGrood, CPPB  
Purchasing Manager

Date

# PRE-PROPOSAL SIGN-IN SHEET

DATE: February 24, 2023 TITLE: Police Weapons Evidence Storage

Project No. 128-23 TIME: 9:00 a.m. ROOM: 9551 Civic Center Drive

| COMPANY NAME                         | CONTACT PERSON | PHONE NO. | E-MAIL ADDRESS   |
|--------------------------------------|----------------|-----------|--|
| 1 City of Thornton Purchasing        | Andrew Miskell | <i>A</i>  | <a href="mailto:Andrew.Miskell@ThorntonCO.gov">Andrew.Miskell@ThorntonCO.gov</a>     |
| 2 Filing World                       | Bill Schuster  | <i>BS</i> | <a href="mailto:Bill@FilingWorld.com">Bill@FilingWorld.com</a>                       |
| 3 Work Space Innovations             | Brycen Bell    | <i>BB</i> | <a href="mailto:Brycen@WorkSpaceInnovations.com">Brycen@WorkSpaceInnovations.com</a> |
| 4 Motus Space Solutions              | Bill Kuntz     | <i>BK</i> | <a href="mailto:BKuntz@MotusSpaceSolutions.com">BKuntz@MotusSpaceSolutions.com</a>   |
| 5 City of Thornton Police Department | <i>Sammy</i>   |           |  |
| 6                                    |                |           |  |
| 7                                    |                |           |  |
| 8                                    |                |           |  |
| 9                                    |                |           |  |
| 10                                   |                |           |  |