

ADDENDUM NO. TWO
PARK SHADE STRUCTURES
PROJECT NO. 20-46D
CITY OF THORNTON, CO

TO: Prospective Bidders and all others concerned

DATE: March 6, 2023

PURPOSE: To provide additional information and clarification to the solicitation documents for the above-referenced Project.

1. The following question and answer is provided for additional clarification to the Contract Documents.

Question 1: "Will the City accept RCP Shelters, Model numbers TS-C2424-4P, TS-SQ20-06, and TS-SS0812-02-CL as 'approved' substitutions?"

Answer 1: Yes, the referenced models are acceptable provided the following:

- All final dimensions, gauges and standards are equivalent to the solicitation design documents.
- Substituted structures allow for (and Contractor includes) solar fixtures as shown in the solicitation documents.
- Final proposed shop drawings include stamped engineered drawings.

2. This Addendum becomes part of the Contract Documents. All other conditions and requirements of the Contract Documents will remain unchanged. Receipt of this Addendum must be acknowledged in the space provided on the Bid Proposal Form in the Project Manual.

END OF ADDENDUM NO. TWO

DocuSigned by:
Jim Jensen
3/6/2023
E057D2786399405...
Jim Jensen Date
Contracts Manager