

**ADDENDUM NO. ONE**  
**INVITATION FOR BID**  
**CONDUIT & PULL BOXES**  
**PROJECT NO. 260-23**  
**CITY OF THORNTON, CO**

TO: Prospective Proposing Firms and all others concerned

DATE: August 18, 2023

PURPOSE: To provide additional information and clarification to the solicitation documents for the above-referenced Project.

1. The following information shall become part of the original Request for Proposal (RFP), or Invitation for Bid (IFB), for this Project.
2. The following questions and answers are provided for additional clarification to the IFB.

*Question 1: For the HDPE pipe that you have on here. That is usually roll pipe that comes in SDR11 or SDR13.5 and you have elbows on the bid for this as well but this pipe does not need elbows. Can you please confirm that this is the correct item for this pipe?*

Answer 1: Elbows are not needed for the HDPE pipe. Please disregard the Elbow, HDPE items listed in **Group B: ELBOWS** of the Proposal Items (C.4).

3. All other terms and conditions shall remain unchanged except as provided by this Addendum. Proposing firms must acknowledge receipt of this Addendum in their Proposal/Bid.

**END OF ADDENDUM NO. ONE**

---

Megan deGrood, CPPB  
Purchasing Manager

Date