

ADDENDUM NO. ONE

GRANGE CREEK IRRIGATION PUMP HOUSE

PROJECT NO. 22-33

CITY OF THORNTON, CO

TO: Prospective Bidders and all others concerned

DATE: December 7, 2023

PURPOSE: To provide additional information and clarification to the solicitation documents for the above-referenced Project.

1. The following shall Add to, Modify, and/or Delete portions of the Project Manual and Drawings for the Project-noted above.

A. The Project Manual shall be modified as follows:

- Bidders shall delete the Reference Authorization and Release Form and replace with the attached, Reference Authorization and Release Form Rev 1.

2. The following questions and answers are provided for additional clarification to the Contract Documents.

Question 1: "For the PS Bldg on Dwg S-101, the Roof Framing Plan shows 2 ea Main Beams of W16 x 15. However, W16 x 15 is not an available size. Did you mean W6 x 15? Please clarify with correct Beam Size."

Answer 1: Yes, Beam Size is W6x15;

Question 2: "Could you provide a connection detail for the L6 x 4 x 5/16 Opening Support Beams connected to the WF Beam?"

Answer 2: Connection should be 3/16" x 4" fillet weld each side (vertical flange) per boxed note (upper right of plan). Cope flange;

Question 3: "What is the condition of the sidewalk?"

Answer 3: Concrete Sidewalk is 6-inches thick. Awarded Contractor should document sidewalk existing condition prior to start of the work. In the event, sidewalk damaged during construction Contractor shall replace using bid item #4 "Remove and replace concrete path;

Question 4: “Who will install pre-purchased pumps, VFD and PLC?”

Answer 4: Installed by Contractor as identified in specification Section 01 10 00 – Summary of Work, 1.8C.

4. This Addendum becomes part of the Contract Documents. All other conditions and requirements of the Contract Documents will remain unchanged. Receipt of this Addendum must be acknowledged in the space provided on the Bid Proposal Form in the Project Manual.

END OF ADDENDUM NO. ONE

DocuSigned by:
Dennis Laurita
12/7/2023
4459E4EFA8C24E5

Dennis Laurita Date
Contracts Supervisor

REFERENCE AUTHORIZATION AND RELEASE FORM Rev 1

By: _____, A Corporation
 _____, A Partnership whose address is:
 (Proposing firm) An Individual

Proposing Firm has submitted a sealed proposal to the City of Thornton (Thornton) for construction services for the Grange Creek Irrigation Pump House, Project No. 22-33 (Project).

Proposing Firm hereby authorizes Thornton to perform such investigation of proposing firm as it deems necessary to verify the qualifications, responsibility, trustworthiness and financial ability of Proposing Firm. By its signature hereon, the proposing firm authorizes Thornton to obtain reference information concerning the proposing firm. Proposing Firm further agrees to release and hold Thornton and the firm or agency providing reference information harmless from all liability resulting from providing the requested reference information to Thornton about the Proposing Firm.

Proposing Firm further authorizes Thornton to discuss and release reference information regarding Proposing Firm's performance as it will relate to this upcoming Project upon receiving a request for such information. Proposing Firm agrees to release and hold Thornton harmless from all liability associated with releasing such information about Proposing Firm.

Proposing Firm further waives its right to receive copies of reference information provided to Thornton. By signing below, Proposing Firm agrees with the terms of this Reference Authorization and Release and authorizes Thornton to obtain reference information concerning Proposing Firm.

A copy or facsimile of this executed Reference Authorization and Release Form may be used with the same effectiveness as an original.

 Signature Date

 Print Name

 Title